

VOC Content Test Certificate

Wednesday April 30th, 2007

Manufacturer: Rockstar Sealing Systems

13/21 Capella Crescent

Moorabbin Victoria 3189

Sample Description: Concrete Sealer

Production Date: May 2007

Date Tested: May 2007

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star IEQ-13	Concrete Sealer
Architectural Sealant 250 grams per Litre	< 1 grams per Litre



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant