

VOC Content Test Certificate

Wednesday April 30th, 2007

Manufacturer: Rockstar Sealing Systems

13/21 Capella Crescent

Moorabbin Victoria 3189

Sample Description: Water-Based Natural Finish Stone Sealer

Production Date: May 2007

Date Tested: May 2007

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification	
Green Building Council of Australia Green Star IEQ-13	Water-Based Natural Finish Stone Sealer
Architectural Sealant 250 grams per Litre	100 grams per Litre



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant